

**KINDER MORGAN ENERGY PARTNERS, L.P.  
SUPPLIER QUALITY CERTIFICATION  
TURBINE FUEL**

**SUPPLIER:** \_\_\_\_\_ **SOURCED THROUGH:** \_\_\_\_\_

**TENDER NO:** \_\_\_\_\_ **DATE:** \_\_\_\_\_

			KMEP Use Only	
Flash Point, °F	D-56	_____	105 °F	_____
Gravity, API	D-1298, D-4052	_____	37.0-51.0	_____
<b>One</b> of the following distillation methods:				
Physical Distillation	D-86			
10% recovered, °F		_____	401 °F max	_____
Final Boiling Point, °F		_____	572 °F max	_____
<b>-- OR --</b>				
Simulated Distillation	D-2887			
10% recovered, °F		_____	365 °F max	_____
Final Boiling Point, °F		_____	644 °F max	_____
Freeze point, °F	D-2386	_____	-40 °F max	_____
Copper strip,	D-130	_____	No. 1	_____
2 h @ 212 °F				
Existent gum	D-381	_____	7 max	_____
Mg/100mL				
Micro Separometer	D-3948	_____	85 min	_____
Particulate Content	D-5452	_____	2.0 mg/L	_____

*(check one)*

This product contains no additives.

This product contains the following approved additives in the amounts specified :

\_\_\_\_\_

This product meets requirements of ASTM D-1655

We certify the above to be true and correct

Authorized Signature \_\_\_\_\_ Date \_\_\_\_\_

Please provide **KMEP Pipeline Input Location** a copy of this completed report by fax at number indicated below for each batch tendered.

<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>	<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>
Concord	(925) 827-2971	(925) 682-6850	Richmond	(510) 232-1729	(510) 233-2027

**KINDER MORGAN ENERGY PARTNERS, L.P.  
SUPPLIER QUALITY CERTIFICATION  
MILITARY JP-5 (1)**

**SUPPLIER:** \_\_\_\_\_ **SOURCED THROUGH:** \_\_\_\_\_

**TENDER NO:** \_\_\_\_\_ **DATE:** \_\_\_\_\_

		<b>KMEP Use Only</b>	
Flash Point, °F	D-93	140°F	_____
Gravity, API	D-1298	36.0-48.0	_____
Workmanship		C & B	_____
Distillation, Deg. F.	D-86, (D-2887)		
10% rec.		401 (367) max	_____
20% rec.		Report	_____
50% rec.		Report	_____
90% rec.		Report	_____
Final Boiling Point, °F		572 (626) max	_____
Residue %		1.5 (n/a) max	_____
Loss %		1.5 (n/a) max	_____
Freeze point, °F (C)	D-2386	-46 (-51) max	_____
Copper Corrosion	D-130	No. 1	_____
2 h @ 212°F			
Existent gum	D-381	7.0 max	_____
Mg/100mL			
Water Reaction	D-1094	1 b max	_____
Particulate Content	D-5452	1.0 mg/L	_____

(1) In addition to above KMEP specifications, product must meet requirements of MIL-DTL-5624U or latest revision.

We certify the above to be true and correct  
 Authorized Signature \_\_\_\_\_ Date \_\_\_\_\_

Please provide **KMEP Pipeline Input Location** a copy of this completed report by fax at number indicated below for each batch tendered.

<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>	<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>
Concord	(925) 827-2971	(925) 682-6850	Richmond	(510) 232-1729	(510) 233-2027
Watson	(310) 763-1698	(323) 636-4447	El Paso	(915) 778-1111	(915) 772-7400

**KINDER MORGAN ENERGY PARTNERS, L.P.  
SUPPLIER QUALITY CERTIFICATION  
MILITARY JP-8 (1)**

**SUPPLIER:** \_\_\_\_\_ **SOURCED THROUGH:** \_\_\_\_\_

**TENDER NO:** \_\_\_\_\_ **DATE:** \_\_\_\_\_

		<b>KMEP Use Only</b>	
Flash Point, °F	D-93	100°F	_____
Gravity, API	D-1298	37.0-51.0	_____
Workmanship		C & B	_____
Distillation, Deg. F.	D-86, (D-2887)		
10% rec.	_____	401 (367) max	_____
20% rec.	_____	Report	_____
50% rec.	_____	Report	_____
90% rec.	_____	Report	_____
Final Boiling Point, °F	_____	572 (626) max	_____
Residue %	_____	1.5 (n/a) max	_____
Loss %	_____	1.5 (n/a) max	_____
Freeze point, °F (C)	D-2386	-47 (-53) max	_____
Copper Corrosion	D-130	No. 1	_____
2 h @ 212°F	_____		
Existent gum	D-381	7.0 max	_____
Mg/100mL	_____		
Water Reaction	D-1094	1 b max	_____
Particulate Content	D-5452	1.0 mg/L max	_____

(1) In addition to above KMEP specifications, product must meet requirements of MIL-DTL-83133F or latest revision.

We certify the above to be true and correct  
 Authorized Signature \_\_\_\_\_ Date \_\_\_\_\_

Please provide **KMEP Pipeline Input Location** a copy of this completed report by fax at number indicated below for each batch tendered.

<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>	<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>
Concord	(925) 827-2971	(925) 682-6850	Richmond	(510) 232-1729	(510) 233-2027
Watson	(310) 763-1698	(323) 636-4447	El Paso	(915) 778-1111	(915) 772-7400